

NOTES:

- 1. Contractor to place meter box in non-traffic area only.
- 2. Meter must be level across meter connections.
- 3. Lock setter with highfield security prod. part#93210142 & 93280148 after waterline testing is completed.



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

3/4" & 1" WATER METER SERVICE DETAIL

SCALE:	DETAIL#
Not To Scale	2519.01
REVISION DATE:	SHEET #:
JAN., 2015	1 of 2